



ARS NORDIC

INSTALLATION GUIDE

Model Code: ARS-N-SMART-QR-EU
Manual Version: v1.0 | 2026
Manufacturer: ARS NORDIC

1. General Information

Installation must be performed by qualified personnel.

2. Wall Opening Requirements

Parameter	Specification
Ventilation duct diameter	Ø125 mm
Wall opening diameter	Ø132 mm
Recommended slope	2-3° outward
Wall thickness compatibility	280-500 mm

3. Installation Steps

- Step 1: Drill Ø132 mm wall opening.
- Step 2: Insert Ø125 mm air duct.
- Step 3: Install external grille.
- Step 4: Install internal unit.
- Step 5: Connect electrical supply.
- Step 6: Test system operation.

4. Electrical Connection

Power supply: 230V AC, 50Hz. Electrical installation must be performed by qualified electrician.

5. Final Check

Ensure correct airflow, secure installation, and proper electrical operation.

ARS NORDIC | Northern Europe Climate Technologies
www.arsnordic.com